

# Extreme Safety Quick Reference Guide

## Insulated Gloves and Mats - Voltage Classes

Class (ASTM & EN Standards)	Working Voltage (V)
Class 00	500V
Class 0	1000V
Class 1	7,500V
Class 2	17,000V
Class 3	26,500V
Class 4	36,000V

**NOTE:** This information should be used as a guide only. Refer to website or contact our customer service representative for more information regarding Extreme Safety Gloves and Mats, including information about the correct working applications.

Maintain a safe work environment - Extreme Safety recommends regular 6 month HV testing of these products. Refer to your State Electrical or Safety Government department to check your local legislation regarding testing. Our NATA approved laboratory can carry out testing.

Contact us for more information.

